



TOWN OF APPOMATTOX

2020 WATER QUALITY REPORT

INTRODUCTION

This Annual Drinking Water Quality Report for calendar year 2020 is designed to inform you about your drinking water quality. Our goal is to provide you with a safe and dependable supply of drinking water, and we want you to understand the efforts we make to protect your water supply. The quality of your drinking water must meet state and federal requirements administered by the Virginia Department of Health (VDH).

If you have questions about this report, want additional information about any aspect of your drinking water, or want to know how to participate in decisions that may affect the quality of your drinking water, please contact David A. Carter, Water Treatment Manager, at our office (434) 352-8268, Monday through Friday during regular office hours (8:30 AM-4:30 PM). The Appomattox Town Council meets on the second Monday of each month at 7:30 p.m. at the Appomattox Municipal Building, 210 Linden Street, Appomattox, Virginia.

GENERAL INFORMATION

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: (1) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. (2) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or framing. (3) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses. (4) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems. (5) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure the tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

Water from surface sources is treated to make it drinkable while groundwater may or may not have any treatment. All drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information may be obtained by calling the Environmental Protective Agency's Safe Drinking Water Hotline (800-426-4791).

VULNERABLE POPULATIONS

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other *microbiological* contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

SOURCES AND TREATMENT OF YOUR DRINKING WATER

The source of your water is surface water from Big Otter River which is treated at a conventional surface water treatment plant for the Central Water System, which is owned by the Campbell County utilities and Service Authority (CCUSA). This water is produced by the Otter River Filter Plant, located in Evington, Virginia. Attached to this report you will find information regarding the source of water from the Campbell County Utility Service Authority (CCUSA).

SOURCE WATER ASSESSMENT REPORTS – (SWAR)

A source water assessment of the Central Water System was conducted in 2003 by the Virginia Department of Health. The water sources were determined to be highly susceptible to contamination using the criteria developed by the State in its approved Source Water Assessment Program. This report was developed by the VDH and is the first step in assisting in the preparation of a Source Water Protection Program (SWPP). A SWAR consists of maps showing the source water assessment area, an inventory of known land use activities of concern and documentation of any known contaminant within the last 5 years. The report is available by contacting your water system representative at the phone number or address given elsewhere in the drinking water quality report.

PUBLIC EDUCATION- LEAD IN DRINKING WATER

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Appomattox is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safe>

PUBLIC EDUCATION- SODIUM IN DRINKING WATER

There is no State or Federal MCL for Sodium. Monitoring is required to provide information to consumers and health officials that are concerned about sodium intake due to dietary restrictions. The sodium level in the water provided by CCUSA was measured at 11.1 ppm in 2020. This is less than EPA recommended optimal level of less than 20 ppm, established for people on a “strict” sodium intake diet.

VIOLATION INFORMATION

The Town of Appomattox has not received a violation since 2005.

In the tables on pages 4 and 5 and elsewhere in this report you will find terms and abbreviations you might not be familiar with. The following definitions are provided to help you better understand these terms:

DEFINITIONS

N/A- Not Applicable

< - Less Than

Action Level (AL) - the concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Residual Disinfection Goal (MRDLG) – the level of a drinking water disinfectant below which there is no known or expected risk to health.

Maximum Residual Disinfection Level (MRDL) - the highest level of a disinfectant allowed in drinking water.

Nephelometric Turbidity Unit (NTU) – nephelometric turbidity unit is a measure of the cloudiness of water, Turbidity in excess of 5 NTU is just noticeable to the average person.

Non-Detects (ND) – lab analysis indicates the contaminant is not detectable, based on the limits of the analytical equipment used.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or one penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (µg/l) – one part per billion corresponds to one minute in 2,000 years, or one penny in \$10,000,000.

Picocuries per liter (pCi/l) - picocuries per liter is a measure of the radioactivity in water.

Primary Maximum Contaminant Level (PMCL)- the maximum allowable level of any particular contaminant.

Running Annual Average (RAA) – The average of the most recent four quarters of sampling.

Secondary Maximum Contaminant Level (SMCL) - the highest level recommended for a contaminant in drinking water, based on aesthetic considerations.

Treatment Technique (TT) – a required process intended to reduce the level of a contaminant in drinking water.

WATER QUALITY RESULTS

Contaminants in your drinking water are routinely monitored according to federal and state regulations. The table on page 4 and 5 of this report shows the results of this monitoring. Most of the water quality results in the tables are from testing done in 2020. However, the state allows us to monitor for some contaminants less than once per year, because the concentrations of these contaminants do not change frequently. Some of our results, though representative, are more than one year old. The tables list only those contaminants that had some level of detection within the last 5 years. Many other contaminants have been analyzed but were not present or were below the detection limits of the lab equipment.

5011050 Appomattox Water System – 2020

| Lead and Copper | | | | | | |
|--|-------------|------------|--|------------|-------------------|--|
| Contaminant / Unit of Measurement | MCLG | MCL | Level Found/Range | Exceedance | Date of Sample | Typical Source of Contamination |
| Lead ppb | 0 | AL= 15 | All Non Detect Of the ten samples collected none exceeded the AL. | No | August 2018 | Corrosion of household plumbing systems; Erosion of natural deposits |
| Copper ppm | 1.3 | AL= 1.3 | 0.03 ND - 0.03 None exceeded the AL. | No | August 2018 | Corrosion of household plumbing systems |
| Disinfection Byproducts | | | | | | |
| Contaminant / Unit of Measurement | MCLG | MCL | Level Found/Range | Violation | Date of Sample | Typical Source of Contamination |
| TTHMs (Total Trihalomethanes) ppb | N/A | 80 | Highest RAA: 71 Range: 33-130 | No | Quarterly 2020 | By-product of drinking water disinfection |
| HAA5s (Total Haloacetic Acids) ppb | N/A | 60 | Highest RAA: 31 Range: 24-36 | No | Quarterly 2020 | By-product of drinking water disinfection |
| Chlorine ppm | MRDLG =4 | MRDL =4 | Average: 1.04 Range: 0.29-2.33 | No | Monthly 2020 | Water additive used to control microbes |

*Compliance with state and federal standards for drinking water for TTHMs and HAA5s is based on the average of four consecutive quarterly samples.

We are pleased to report to you that there were no detections of total coliforms or fecal coliforms in the monthly samples collected during calendar year 2020.

Unregulated Contaminant Rule 4 (UCMR4) – 2020

| Contaminant / Unit of Measurement | MCLG | MCL | Level Found/Range | Violation | Date of Sample | Typical Source of Contamination |
|---|------|-----|---------------------------|-----------|-----------------------------------|---|
| Manganese ppb | N/A | 50 | 0.495 5.500 | No | January 13, 2020 July 14, 2020 | By-product of drinking water disinfection |
| HAA5 ppb | N/A | 60 | Range: 27.186 – 39.430 | No | Quarterly 2020 | By-product of drinking water disinfection |
| HAA6Br ppb | N/A | N/A | Range: 3.40 – 7.54 | No | Quarterly 2020 | By-product of drinking water disinfection |
| HAA9 ppb | N/A | N/A | Range: 32.118 – 46.540 | No | Quarterly 2020 | By-product of drinking water disinfection |

* Unregulated contaminant monitoring helps EPA to determine where certain contaminants occur and whether it need to regulate those contaminants.

OTTER RIVER WATER TREATMENT PLANT- 2020

| Contaminant/ Unit of Measurement | MCLG | MCL | Highest Level and Range | Violation | Typical Source of Contamination |
|--|------|--|---|-----------|--|
| Fluoride, ppm | 4 | 4 | 0.75 (average) 0.59 -1.01 (range) | NO | Erosion of natural deposits; Water additives which promotes strong teeth; Discharge from fertilizer and aluminum factories |
| Nitrate + Nitrite (as Nitrogen), ppm | 10 | 10 | 0.21 | NO | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits |
| Turbidity, NTU | n/a | 1.0 Max TT 0.3 in 95% of monthly samples | 0.05 (highest level) 100% < 0.3 | NO | Soil runoff |
| Total Organic Carbon, (TOC) | n/a | TT Ratio \geq 1.0 | 1.14 (Avg. removal ratio) 1.00 -1.30 (range) | NO | Naturally present in the environment |
| ² Gross Alpha, pCi/L | 0 | 15 | < 0.33 | NO | Erosion of natural deposits |
| ² Radium-228, pCi/L | 0 | 5 | < 0.66 | NO | Erosion of natural deposits |
| Barium ppm | 2 | 2 | 0.013 mg/L | NO | Discharge of drilling wastes: discharge from metal refineries: Erosion of natural deposits. |

¹ Data from 2018. Next required sampling period in 2021. ² Data from 8/6/2020.